

Search Results



You are here: [Home](#) » Search Results

Alarm warning devices

Syncoln Ltd

3rd Floor
14 Hanover Street
Mayfair
London
W1S 1YH
United Kingdom

Tel: +44 (0)207 514 5813

Email: sales@syncoln.com • Web: www.syncoln.com

Certificate No 717e-(cl-1) to EN 54-23:2010

Visual Warning Devices

Product	Description	LPCB Ref. No.
1000-300	<p>Conventional Type A Wall Mounted White Light LED Visual Alarm Device (red head / red bases) - (PSO-0001 base)</p> <p>Note:</p> <ol style="list-style-type: none"> The wall mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> Category W-3.1-11.3 Flash rates 0.5Hz and 1Hz Synchronization 	717e/03

See below for all products listed in this group including notes.

Visual Warning Devices

Product	Description	LPCB Ref. No.
1000-300	<p>Conventional Type A Wall Mounted White Light LED Visual Alarm Device (red head / red bases) - (PSO-0001 base)</p> <p>Note:</p> <ol style="list-style-type: none"> The wall mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> Category W-3.1-11.3 Flash rates 0.5Hz and 1Hz Synchronization 	717e/03
1000-301	<p>Conventional Type B Wall Mounted White Light LED Visual Alarm Device (red head / red bases) - (PSO-0017)</p> <p>Note:</p> <ol style="list-style-type: none"> The wall mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> Category W-3.1-11.3 Flash rates 0.5Hz and 1Hz Synchronization 	717e/03

Bases
PSO-0001 Red shallow base
PSO-0017 Red deep base

[To read the Red Book section introduction click here.](#)

[< back to results page](#)

LPCB®



twitter

facebook

LinkedIn

The BRE Group website family

BRE Trust bre BRE BOOKSHOP SMARTWASTE™ breinnovation park GreenGuide

BRE Global Approvals listings

RedBookLive GreenBookLive BREEAM®

[Terms of Use](#) | [How we use cookies](#) | Copyright BRE Global 2020