

Certificate of Product Approval

Certificate Number: 010ag

Issue: 17

Apollo Fire Detectors Limited

36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Line Units

XP95 Range of Line Units, S65 Conventional Relay
Bases and Orbis Bases
(refer to Appendix for details)

Standards

EN 54-18:2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

12 December 2019

Date of Issue

10 March 2009

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 010ag Apollo Fire Detectors Limited

Issue: 17

Certified Product	Description	LPCB Ref.No.
45681-242	XP95 Analogue Addressable Low Power Relay Base	010ag/01
45681-245	S65 Conventional Standard Relay Base	010ag/02
45681-246	S65 Conventional Auxiliary Relay Base	010ag/03
45681-247	S65 Conventional end of line 12V Relay Base	010ag/04
45681-248	S65 Conventional end of line 24V Relay base	010ag/05
45681-508	S65 Conventional 12V Relay Base	010ag/06
55000-181	XP95 Analogue Addressable DIN-rail 8A Sounder Controller Unit	010ag/07
55000-182	XP95 Analogue Addressable DIN-rail Sounder Control Unit	010ag/08
55000-797	XP95 Analogue Addressable DIN-rail Mains Input/Output Unit Note: To ensure compliance is maintained, this device shall be installed within an enclosure weighing greater than 4.75kg.	010ag/09
55000-855	XP95 Analogue Addressable DIN-rail Protocol Translator - Single Note: To ensure compliance is maintained, all connecting cables to the protocol translator shall be less than 3m.	010ag/14
55000-856	XP95 Analogue Addressable DIN-rail Protocol Translator - Dual Note: To ensure compliance is maintained, all connecting cables to the protocol translator shall be less than 3m.	010ag/15
ORB-RB-10004	Orbis TimeSaver Relay Base	010ag/17
ORB-SW-10005	Orbis Sav-wire Base	010ag/18

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Halligan

Signed for BRE Global Ltd

P Halligan
Verifier

12 December 2019
Date of Issue

10 March 2009
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 010ag Apollo Fire Detectors Limited

Issue: 17

Alternative Model No./Label

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
010ag/01	45681-242	EBI-20	Schneider Electric Fire & Security Oy	010ag-(cl-1)
010ag/02	45681-245	45681-245AMP	AMPAC Technologies PTY Ltd	010ag-(cl-2)
010ag/02	45681-245	200-303	Eurotech Fire Systems Ltd	1213g
010ag/08	55000-182	EMI-401S	Schneider Electric Fire & Security Oy	010ag-(cl-1)
010ag/14	55000-855	SIL-A9099	Shield Fire, Safety and Security Ltd	010ag-(cl-4)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Halligan

Signed for BRE Global Ltd

P Halligan
Verifier

12 December 2019
Date of Issue

10 March 2009
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre