



Search Results



You are here: [Home](#) » Search Results

Alarm warning devices

Texecom Ltd

Bradwood Court
St Crispin Way
Haslingden
Lancashire
BB4 4PW
United Kingdom

Tel: +44 (0)1706 220460 • Fax: +44 (0)1706 230692
Email: sales@texe.com • Web: <http://www.texe.com>

Certificate No 717a to EN 54-3: 2001 + A1: 2002 + A2: 2006

Certificate No 717d to EN 54-23: 2010 & EN 54-3: 2001 + A1: 2002 + A2: 2006

Certificate No 717e to EN54-23: 2010

Product	Description	LPCB Ref. No.
PSS-0089	<p>Sonos DC Sounder Wide Voltage (White)</p> <p>(PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 	717a/06

See below for all products listed in this group including notes.

Product	Description	LPCB Ref. No.
PSS-0068	<p>Conventional Sounder with LED Strobe (Red Head / Red Base)</p> <p>(PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 	717a/01
PSS-0079	<p>Conventional Sounder with LED Strobe (Red Head / White Base)</p> <p>(PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> The above sounder is Type A when used the with the shallow base & Type B 	717a/02

	<p><i>when used with the deep base only</i></p> <p>2. <i>Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13</i></p>	
PSS-0073	<p>Conventional Sounder with LED Strobe (Amber Head / Red Base)</p> <p>(PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <p>1. <i>The above sounder is Type A when used the with the shallow base & Type B</i> <i>when used with the deep base only</i></p> <p>2. <i>Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13</i></p>	717a/03
PSS-0080	<p>Conventional Sounder with LED Strobe (Amber Head / White Base)</p> <p>(PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <p>1. <i>The above sounder is Type A when used the with the shallow base & Type B</i> <i>when used with the deep base only</i></p> <p>2. <i>Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13</i></p>	717a/04
PSS-0084	<p>Sonos DC Sounder Wide Voltage (Red)</p> <p>(PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <p>1. <i>The above sounder is Type A when used the with the shallow base & Type B</i> <i>when used with the deep base only</i></p> <p>2. <i>Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13</i></p>	717a/05
PSS-0089	<p>Sonos DC Sounder Wide Voltage (White)</p> <p>(PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <p>1. <i>The above sounder is Type A when used the with the shallow base & Type B</i> <i>when used with the deep base only</i></p> <p>2. <i>Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13</i></p>	717a/06
PBS-0003	<p>Universal base sounder (White)</p> <p>Notes:</p> <p>1. <i>Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13</i></p>	717a/07
PBS-0009	<p>Universal base sounder (Cream)</p> <p>Notes:</p> <p>1. <i>Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13</i></p>	717a/08
PSC-0045	<p>Conventional Sounder with LED Strobe Common Operation</p> <p>(Red Head / Red Base)</p> <p>(PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <p>1. <i>The above sounder is Type A when used the with the shallow base & Type B</i> <i>when used with the deep base only</i></p> <p>2. <i>Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13</i></p>	717a/10
PSC-0051	<p>Conventional Sounder with Red LED Strobe Common Operation</p> <p>(Clear Lens / White Base)</p> <p>(PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <p>1. <i>The above sounder is Type A when used the with the shallow base & Type B</i> <i>when used with the deep base only</i></p> <p>2. <i>Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13</i></p>	717a/11

PSC-0054	<p>Conventional Sounder with LED Strobe Common Operation (Amber Head / Red Base) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only 2. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 	717a/12
PSC-0055	<p>Conventional Sounder with Red LED Strobe (Clear Lens / White Base) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only 2. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 	717a/13
PBS-0015	<p>Universal base sounder (Red)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 	717a/14
PSC-0062	<p>Conventional Sounder with LED Strobe Common Operation (Red Head / White Base) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only 2. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 	717a/16
PSC-0063	<p>Conventional Sounder with LED Strobe Common Operation (Amber Head / White Base) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only 2. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 	717a/17
ESCA3000R	<p>Conventional Type A sounder and ceiling mounted white light LED visual alarm device (red head / red base) - (PSO-0001 / 18- 185856-2, PSO-0017 / HSG6918 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. The sounder meets the requirements of EN 54-3:2001 at tones 1, 2, 3, 6, 7 & 13 2. The ceiling mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> - Category C-3-15 - Flash rates 0.5Hz and 1Hz - Synchronization 	717d/01
ESCA3000W	<p>Conventional Type A sounder and ceiling mounted white light LED visual alarm device (white head / white base) - (PSO-0006 / 18-186049-2, PSO-0018 / HSG6917 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. The sounder meets the requirements of EN 54-3:2001 at tones 1, 2, 3, 6, 7 & 13 2. The ceiling mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> - Category C-3-15 	717d/02

	<ul style="list-style-type: none"> - Flash rates 0.5Hz and 1Hz - Synchronization 	
ESCA4000R	<p>Conventional Type A sounder and wall mounted white light LED visual alarm device (red head / red base)</p> <p>- (PSO-0001 / 18-185856-2, PSO-0017 / HSG6918 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. The sounder meets the requirements of EN 54-3:2001 at tones 1, 2, 3, 6, 7 & 13 2. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> - Category W-3.1-11.3 - Flash rates 0.5Hz and 1Hz - Synchronization 	717d/03
ESCA4000W	<p>Conventional Type A sounder and wall mounted white light LED visual alarm device (white head / white base)</p> <p>- (PSO-0006 / 18-186049-2, PSO-0018 / HSG6917 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. The sounder meets the requirements of EN 54-3:2001 at tones 1, 2, 3, 6, 7 & 13 2. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> - Category W-3.1-11.3 - Flash rates 0.5Hz and 1Hz - Synchronization 	717d/04
ESBA3000R	<p>Conventional Type A/B ceiling mounted white light LED visual alarm device (red head / red bases)</p> <p>- (PSO-0001 / 18-185856-2, PSO-0017 / HSG6918 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. The VAD is Type A when used with the shallow base & Type B with the deep base. 2. The ceiling mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> - Category C-3-15 - Flash rates 0.5Hz and 1Hz - Synchronization 	717e/01
ESBA3000W	<p>Conventional Type A/B ceiling mounted white light LED visual alarm device (white head / white bases)</p> <p>- (PSO-0006 / 18-186049-2, PSO-0018 / HSG6917 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. The VAD is Type A when used with the shallow base & Type B with the deep base. 2. The ceiling mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> - Category C-3-15 - Flash rates 0.5Hz and 1Hz - Synchronization 	717e/02
ESBA4000R	<p>Conventional Type A/B wall mounted white light LED visual alarm device (red head / red bases)</p> <p>- (PSO-0001 / 18-185856-2, PSO-0017 / HSG6918 bases)</p> <p>Notes:</p>	717e/03

	<p>1. The VAD is Type A when used with the shallow base & Type B with the deep base.</p> <p>2. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following:</p> <ul style="list-style-type: none"> - Category W-3.1-11.3 - Flash rates 0.5Hz and 1Hz - Synchronization 	
ESBA4000W	<p>Conventional Type A/B wall mounted white light LED visual alarm device (white head / white bases)</p> <p>- (PSO-0006 / 18-186049-2, PSO-0018 / HSG6917 bases)</p> <p>Notes:</p> <p>1. The VAD is Type A when used with the shallow base & Type B with the deep base.</p> <p>2. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following:</p> <ul style="list-style-type: none"> - Category W-3.1-11.3 - Flash rates 0.5Hz and 1Hz - Synchronization 	717e/04
ESDA2000R	<p>Conventional Type A/B Ceiling Mounted Red Light LED Visual Alarm Device (Red Head / Red Bases)</p> <p>- (PSO-0001 / 18-185856-2, PSO-0017 / HSG6918 Bases)</p> <p>Notes:</p> <p>1. The VAD is Type A when used with the shallow base & Type B with the deep base.</p> <p>2. The ceiling mounted VAD meets the requirements of EN 54-23:2010 for the following:-</p> <ul style="list-style-type: none"> - Category C-3-8.9 - Flash rates 0.5Hz and 1Hz - Synchronization 	717e/05
ESDA2000W	<p>Conventional Type A/B Ceiling Mounted Red Light LED Visual Alarm Device (White Head / White Bases) - (PSO-0006 / 18-186049-2, PSO-0018 / HSG6917 Bases)</p> <p>Notes:</p> <p>1. The VAD is Type A when used with the shallow base & Type B with the deep base.</p> <p>2. The ceiling mounted VAD meets the requirements of EN 54-23: 2010 for the following:-</p> <ul style="list-style-type: none"> - Category C-3-8.9 - Flash rates 0.5Hz and 1Hz - Synchronization 	717e/06
ESDA1000R	<p>Conventional Type A/B Wall Mounted Red Light LED Visual Alarm Device (Red Head / Red Bases)</p> <p>- (PSO-0001 / 18-185856-2, PSO-0017 / HSG6918 Bases)</p> <p>Notes:</p> <p>1. The VAD is Type A when used with the shallow base & Type B with the deep base.</p> <p>2. The wall mounted VAD meets the requirements of EN 54-23: 2010 for the following:-</p> <ul style="list-style-type: none"> - Category W-2.4-7.5 - Flash rates 0.5Hz and 1Hz - Synchronization 	717e/07
ESDA1000W	<p>Conventional Type A/B Wall Mounted Red Light LED Visual Alarm Device (White Head / White Bases)</p> <p>- (PSO-0006 / 18-186049-2, PSO-0018 / HSG6917 Bases)</p> <p>Notes:</p> <p>1. The VAD is Type A when used with the shallow base & Type B with the deep base.</p> <p>2. The wall mounted VAD meets the requirements of EN 54-23: 2010 for the following:-</p> <ul style="list-style-type: none"> - Category W-2.4-7.5 - Flash rates 0.5Hz and 1Hz - Synchronization 	717e/08
ESFA2000R	<p>Conventional Type A Sounder and Ceiling Mounted Red Light LED Visual Alarm Device (Red Head / Red Base)</p> <p>- (PSO-0001 / 18- 185856-2, PSO-0017 / HSG6918 Bases)</p>	717d/05

	<p>Notes:</p> <ol style="list-style-type: none"> The sounder meets the requirements of EN 54-3: 2001 at the following tones:- <ol style="list-style-type: none"> 970Hz continuous, 800Hz/970Hz @ 2Hz, 800Hz - 970Hz @ 1Hz, 554Hz, 0.1s/ 440Hz, 0.4s, 500 - 1200Hz, 3.5s/ 0.5s OFF 1200Hz - 500Hz @ 1Hz The ceiling mounted VAD meets the requirements of EN 54-23: 2010 for the following:- <ul style="list-style-type: none"> Category C-3-8.9 Flash rates 0.5Hz and 1Hz Synchronization 	
ESFA2000W	<p>Conventional Type A Sounder and Ceiling Mounted Red Light LED Visual Alarm Device (White Head / White Base)</p> <p>- (PSO-0006 / 18-186049-2, PSO-0018 / HSG6917 Bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> The sounder meets the requirements of EN 54-3:2001at the following tones:- <ol style="list-style-type: none"> 970Hz continuous, 800Hz/970Hz @ 2Hz, 800Hz - 970Hz @ 1Hz, 554Hz, 0.1s/ 440Hz, 0.4s, 500 - 1200Hz, 3.5s/ 0.5s OFF 1200Hz - 500Hz @ 1Hz The ceiling mounted VAD meets the requirements of EN 54-23:2010 for the following:- <ul style="list-style-type: none"> Category C-3-8.9 Flash rates 0.5Hz and 1Hz Synchronization 	717d/06
ESFA1000R	<p>Conventional Type A Sounder and Wall Mounted Red Light LED Visual Alarm Device (Red Head / Red Base)</p> <p>- (PSO-0001 / 18-185856-2, PSO-0017 / HSG6918 Bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> The sounder meets the requirements of EN 54-3:2001at the following tones:- <ol style="list-style-type: none"> 970Hz continuous, 800Hz/970Hz @ 2Hz, 800Hz - 970Hz @ 1Hz, 554Hz, 0.1s/ 440Hz, 0.4s, 500 - 1200Hz, 3.5s/ 0.5s OFF 1200Hz - 500Hz @ 1Hz The wall mounted VAD meets the requirements of EN 54-23:2010 for the following:- <ul style="list-style-type: none"> Category W-2.4-7.5 Flash rates 0.5Hz and 1Hz Synchronization 	717d/07
ESFA1000W	<p>Conventional Type A sounder and wall mounted red light LED visual alarm device (white head / white base)</p> <p>- (PSO-0006 / 18-186049-2, PSO-0018 / HSG6917 bases)</p> <p>Notes:</p> <ol style="list-style-type: none"> The sounder meets the requirements of EN 54-3:2001at the following tones:- <ol style="list-style-type: none"> 970Hz continuous, 800Hz/970Hz @ 2Hz, 800Hz - 970Hz @ 1Hz, 554Hz, 0.1s/ 440Hz, 0.4s, 500 - 1200Hz, 3.5s/ 0.5s OFF 1200Hz - 500Hz @ 1Hz The wall mounted VAD meets the requirements of EN 54-23:2010 for the following:- 	717d/08

	<ul style="list-style-type: none"> - Category W-2.4-7.5 - Flash rates 0.5Hz and 1Hz - Synchronization 	
ESFA1000G	<p>Conventional Type A Sounder and Wall Mounted Red Light LED Visual Alarm Device (grey head / grey base)</p> <p>(PSO-0022 base)</p> <p>Notes:</p> <p>The sounder meets the requirements of EN 54-3:2001 at the following tones:</p> <p>970Hz continuous 800Hz/970Hz @ 2Hz 800Hz - 970Hz @ 1Hz 554Hz, 0.1s / 440Hz, 0.4s 500 - 1200Hz, 3.5s / 0.5s OFF 1200Hz - 500Hz @ 1Hz</p> <p>2. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following:</p> <p>Category W-2.4-7.5 Flash rates 0.5Hz and 1Hz Synchronization</p>	717d/09
PSS-0151	<p>Sonos DC Sounder Wide Voltage (Grey)</p> <p>(PSO-0022 base)</p> <p>Notes:</p> <p>Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 Approved to Type A Indoor use only</p>	717a/18

Bases:

PSO-0001 Shallow base (red)
PSO-0006 Shallow base (white)
PSO-0003 Deep base (red)
PSO-0007 Deep base (white)
PSO-0001 / 18-185856-2 Red shallow base
PSO-0017 / HSG6918 Red deep base
PSO-0006 / 18-186049-2 White shallow base
PSO-0018 / HSG6917 White deep base
PSO-0022 Sonos Grey Shallow Base

[To read the Red Book section introduction click here.](#)

[< back to results page](#)

LPCB[®]



[twitter](#)
[facebook](#)
[Linked in](#)

The BRE Group website family

BRE Global Approvals listings

BRE Trust
bre
BRE BOOKSHOP
SMARTWASTE[®]
breinnovation park
GreenGuide

RedBookLive
GreenBookLive
BREEAM[®]

[Terms of Use](#) | [How we use cookies](#) | Copyright BRE Global 2020